

DEKLARACJA WŁAŚCIWOŚCI UŻYTKOWYCH

Nr 2797-CPR-535595

Zgodnie z rozporządzeniem o wyrobach budowlanych UE nr 305/2011

Unikalny kod identyfikacyjny typu produktu:	Marka(i): Kidde Model(e): <i>patrz Wykaz modeli</i>
Typ, partia lub numer seryjny:	<i>Każdy pojedynczy produkt jest identyfikowany za pomocą etykiety zawierającej unikalny numer seryjny</i>
Przeznaczenie:	Bezpieczeństwo pożarowe (budynki mieszkalne, mieszkania i pomieszczenia o podobnym przeznaczeniu)
Nazwa, zarejestrowana nazwa handlowa lub zarejestrowany znak towarowy i adres kontaktowy producenta:	Walter Kidde Portable Equipment Inc 1016 Corporate Park Drive Mebane, NC 27302, USA
Nazwa i adres kontaktowy upoważnionego przedstawiciela:	Carrier Fire & Security B.V. Kelvinstraat 7, 6003 DH Weert, NL
System lub systemy AVCP:	System 1
Deklaracja właściwości użytkowych dotycząca wyrobu budowlanego jest objęta normą zharmonizowaną:	BSI Group The Netherlands B.V. – 2797 , przeprowadziła badania typu, wstępną inspekcję zakładu produkcyjnego i zakładowej kontroli produkcji z oceną ciągłego nadzoru i zatwierdzeniem zakładowej kontroli produkcji w ramach systemu 1 oraz wydała certyfikat stałości właściwości użytkowych: 2797 CPR 535595 .

Deklarowane właściwości użytkowe:

Podstawowa charakterystyka	Właściwości użytkowe	Zharmonizowana specyfikacja techniczna: EN 14604+AC:2008
Nominal activation conditions / sensitivity / response delay (response time) and performance under fire conditions		
Smoke alarm signals	Pass	4.12
Inter-connectable smoke alarms	Pass	4.18
Repeatability	Pass	5.2
Directional dependence	Pass	5.3
Initial sensitivity	Pass	5.4
Air movement	Pass	5.5
Dazzling	Pass	5.6
Fire sensitivity	Pass	5.15
Sound output	Pass	5.17
Sounder durability	Pass	5.18
Inter-connectable smoke alarms	Pass	5.19
Alarm silence facility	Pass	5.20
Operational reliability		
Compliance	Pass	4.1
Individual alarm indicator	Pass	4.2
Mains-on indicator	Pass	4.3
Connection of external ancillary devices	Pass	4.4
Means of calibration	Pass	4.5
User replaceable components	Pass	4.6
Normal power source	Pass	4.7
Standby power source	Pass	4.8

Podpis przedstawiciela/producenta:



Tomasz Dowgiałło, Lider ds. zgodności z normami
Carrier Fire & Security B.V.
Kelvinstraat 7, 6003 DH Weert,
Holandia

Electrical safety requirements	Pass	4.9
Routine test facility	Pass	4.10
Terminals for external conductors	Pass	4.11
Battery removal indication	Pass	4.13
Battery connections	Pass	4.14
Battery capacity	Pass	4.15
Protection against the ingress of foreign bodies	Pass	4.16
Additional requirements for software controlled smoke alarms	Pass	4.17
Marking and data	Pass	4.19
Impact	Pass	5.11
Battery fault warning	Pass	5.16
Battery reversal	Pass	5.22
Back-up power source	Pass	5.23
Electrical safety – assessment and testing to determine the adequacy of personal protection against hazardous currents passing through the human body (electric shock), excessive temperature and the start and spread of fire	Pass	5.24
Tolerance to supply voltage		
Variation in supply voltage	Pass	5.21
Durability of operational reliability, temperature resistance		
Dry heat (operational)	Pass	5.7
Cold (operational)	Pass	5.8
Durability of operational reliability, vibration resistance		
Vibration (operational)	Pass	5.12
Vibration (endurance)	Pass	5.13
Durability of operational reliability, humidity resistance		
Damp heat (operational)	Pass	5.9
Durability of operational reliability, corrosion resistance		
Sulphur dioxide (SO ₂) corrosion (endurance)	Pass	5.10
Durability of operational reliability, electrical stability		
Electromagnetic compatibility (EMC), immunity (operational)	Pass	5.14

Właściwości użytkowe wyrobu określonego powyżej są zgodne z zestawem deklarowanych właściwości użytkowych. Niniejsza deklaracja właściwości użytkowych została wydana, zgodnie z rozporządzeniem (UE) nr 305/2011, na wyłączną odpowiedzialność producenta określonego powyżej.

Wykaz modeli (Wykaz wszystkich wariantów produktu lub modeli, dla których niniejsza deklaracja jest ważna):

Model	Opis
10Y29	Battery powered Photoelectric Smoke Alarm with Alarm Silence Function and Non-replaceable Long Life Battery
10SCO	Battery powered Combined Photoelectric Smoke and CO Alarm with Alarm Silence Function and User-replaceable Battery
1SFW	Mains powered Ionisation Smoke Alarm with Battery Back-up, Interconnect and Alarm Silence Function
1SFWR	Mains powered Ionisation Smoke Alarm with Re-chargeable Battery Back-up, Interconnect and Alarm Silence Function
2SFW	Mains powered Photoelectric Smoke Alarm with Alarm Silence and Back-up Battery
2SFWR	Mains powered Photoelectric Smoke Alarm with Alarm Silence and Non-replaceable Battery Back-up
KF10	Mains powered Ionisation Smoke Alarm with Replaceable Battery Back-up, Interconnect and Alarm Silence Function
KF10R	Mains powered Ionisation Smoke Alarm with Non-replaceable rechargeable lithium Battery Back-up, Interconnect and Alarm Silence Function
KF10LL	Mains powered Ionisation Smoke Alarm with Replaceable Lithium Battery Back-up, Interconnect and Alarm Silence Function
KF20	Mains powered Photoelectric Smoke Alarm with Replaceable Battery Back-up, Alarm Silence and Interconnect Function
KF20R	Mains powered Photoelectric Smoke Alarm with Alarm Silence and Interconnect Function and Non-replaceable Rechargeable Lithium Battery Back-up,

Podpis przedstawiciela/producenta:



Tomasz Dowgiałło, Lider ds. zgodności z normami
Carrier Fire & Security B.V.
Kelvinstraat 7, 6003 DH Weert,
Holandia

KF20LL	Mains powered Photoelectric Smoke Alarm with Replaceable Lithium Battery Back-up, Alarm Silence and Interconnect Function
--------	---

Rozporządzenie (UE) Nr 305/2011 o wyrobach budowlanych. Dodatkowe informacje dotyczące oznakowania CE



Identyfikacja Jednostki Certyfikującej: 2797

Producent: Walter Kidde Portable Equipment Inc

1016 Corporate Park Drive

Mebane, NC 27302, USA

Dwie ostatnie cyfry roku, w którym znak CE został umieszczony po raz pierwszy: 08

Numer Deklaracji Właściwości Użytkowych (DWU): 2797-CPR-535595

Norma EN: EN 14604+AC:2008

Unikalny kod identyfikacyjny typu produktu: Numer części i rewizja dokumentacji produktu znajdują się na etykiecie produktu

Przeznaczenie: Fire safety (residential buildings, apartments and rooms with similar purposes)

Zasadnicze charakterystyki: patrz tabela właściwości użytkowych DWU

Pobierz ten dokument w swoim języku z:

www.kiddesafetyeurope.co.uk

admin.kiddesafety@carrier.com

Podpis przedstawiciela/producenta:



Tomasz Dowgiałło, Lider ds. zgodności z normami

Carrier Fire & Security B.V.

Kelvinstraat 7, 6003 DH Weert,

Holandia